

**Response of  
Wisconsin Power and Light Company  
to  
The Public Service Commission of Wisconsin  
Data Request No. 3.05**

Public Service Commission of Wisconsin  
RECEIVED: 03/30/09, 3:52:31 PM

Docket Number: 05-CE-137  
Date of Request: March 11, 2009  
Information Requested By: Ken Detmer  
Date Responded: March 30, 2009  
Author: Jeff Knier  
Author's Title: Project Director CACP  
Author's Telephone No.: (608) 458-4866  
Witness: (If other than Author)

---

**Data Request No. 3.05:**

p. 29 par. 4: Provide update on the need for fan modifications and if the costs of such are included in the total cost.

**Response:**

Since the filing of the Application, WPL has determined that the ID fan rotors and electric motors will need to be upgraded in order to allow for sufficient operational margin with the addition of the SCR equipment. The costs for these upgrades are included as part of the total cost estimate that was included in the Application.